



NOTES:

1. For supply connections use No. 14 AWG or larger wires rated for at least 75°C (167°F). *USE COPPER CONDUCTORS ONLY*.
2. ATTENTION: IF THE TRANSDUCER IS MOUNTED ON A NON-METALLIC OR UNGROUNDED SURFACE THE INSTALLER MUST PROVIDE THE MEANS FOR GROUNDING AND BONDING AS PER NEC (NATIONAL ELECTRIC CODE) REQUIREMENTS.

CONNECTION DIAGRAM

REV	DESCRIPTION	DATE	APPROVAL	NEXT ASSY	USED ON
A	ECN 216133	6/18/97			

UNLESS OTHERWISE SPECIFIED
 DECIMAL .XX ±.020 .XXX ±.010
 FRACTIONAL ±1/64 ANGULAR ±1 DEG
 ALL DIMENSIONS IN INCHES
 () DIMENSIONS IN MILLIMETERS

MEASUREMENT TECHNOLOGIES, LTD
 Voice: 817-442-9930
 Web Site: www.mtech.biz

DRAWN	TALLANT	DATE
ENGR		6/18/97
Q A		
RELEASED		

TITLE					
DIN RAIL MOUNT FREQUENCY TRANSDUCER CONNECTION DIAGRAM					
SCALE	SIZE	DWG. NO.	REV	SHEET	
-	B	DFREQ-1	A	1 OF 1	

DWG. NO. DFREQ-1
 SHEET 1
 REV A