



NOTES:

1. For supply connections use No. 14 AWG or larger wires rated for at least 75°C (167°F). *USE COPPER CONDUCTORS ONLY*.

ATTENTION:

IF THE TRANSDUCER IS MOUNTED ON A NON-METALLIC OR UNGROUNDED SURFACE THE INSTALLER MUST PROVIDE THE MEANS FOR GROUNDING AND BONDING AS PER NEC (NATIONAL ELECTRIC CODE) REQUIREMENTS

CONNECTION DIAGRAM

REVISION	

MEASUREMENT TECHNOLOGIES, LTD.
Voice: 817-442-9930
Web Site www.mtech.biz

DRAWN	TONY C
CHECKED	T.N.
APPROVED	T.N.
DATE	DEC, 1993

TITLE	
FREQUENCY TRANSDUCER CONNECTION DIAGRAM	
DRAWING No.	SHEET
FREQ-1	1 of 1
REV.	2A